

**SUB DIVISIONAL ENGINEER,
PROVINCIAL SUB DIVISION NO.3,PWD, B&R Br. AMRITSAR**

To

**Principal
Sri Guru Teg Bahadur Public School
Khankot , Amritsar.**

No. 41

Dated:- 13/5/21

Subject:- School Building Safety Certificate for the year 2021-22.

Reference:- Your letter No. 21 dated 03.5.2021

As per the report submitted by Shri Mandeep Singh J.E. The building of Sri Guru Teg Bahadur Public School Khankot , Amritsar has been inspected and found Structurally safe and fit for human habitation for the year 2021-22. The necessary performs I & II of Building safety Certificate submitted by you are herewith duly signed. The Building Safety Certificate is being issued subject to the condition that School should have sanctioned by the competent authority of the Education Department.

DA/ Performa Part-I & II


Sub Divisional Engineer,
Provincial Sub Division No.3
PWD B&R Br., Amritsar.

PROFORMA FOR THE SAFETY CERTIFICATE OF SCHOOL BUILDING

(PART-I)

(To be filled in by the head of school, institute)

Name of the school

Sri Guru Teg Bahadur Public School Kharoket

Location

Plot Area

8.46 Acres

Plinth Area

1.57 Area

Number of stories

Double Storey

Area of Constructed Part of the building

Con/ Area: 68743.98. Sarda F-I

If the building has been constructed under the supervision of the qualified engineer, the following details may be given:-

a. Name of Engineer with qualification.

Er. Sukhmander Singh

b. Address of the Engineer.

Sec-143, B-Block, 5th Floor
Ranjit Avenue - Anandpur

c. If structural drawing used in the construction, if available?

Ranjit Avenue Anandpur

d. Name and address of Architect with qualification.

Sukhmander Singh & Associates

8. Whether the building has been constructed for the purpose of

- a. School
- b. Residential purpose and used for a school.

Yes / No
 Yes/NO

9. Materials used for Roofs

- a. R.C.C. Slabs
- b. R.S. Joists and Battens
- c. Wooden joints and bottom

Yes

10. Material used for walls

- a. Mud Mortar
- b. Cement Mortar
- c. Lime Mortar

Yes/No
Yes/No
Yes/No

11. Flooring

- a. Conglomerate
- b. Terrace
- c. Brick Paving

Yes/No
Yes/No
Yes/No

12. A detailed drawing indicating the doors along with windows and location fitting and windows is attached.

13. FOR FIRE SAFETY

- a. Whether the width of the staircase is 1.5 mtr.
- b. Whether portable fire extinguisher exists.
- c. Whether school building is free from inflammable and toxic material.
- d. Whether cooking of food is done in safe place.
- e. Whether any Thatch or combustible material has been used.

Yes/No
 Yes/ No
 Yes/No
 Yes/No
 Yes/No

**Requirement for Fire Protection Arrangement under NB- Part-IV
(For building height less than 15 meter)**

- | | |
|---|-------------|
| a. Whether Hose Reel provided | ✓
Yes/No |
| b. Whether down comer provided | ✓
Yes/No |
| c. Whether Automatic Sprinkler provided. | ✓
Yes/No |
| d. Whether underground static water storage tank of capacity 50000 Ltr. (if converted area exceeds 1500 sqm) | ✓
Yes/No |
| e. Whether over head tank of capacity 10000 Ltr. Exists (in case of hose reel) 20000 Ltr. | ✓
Yes/No |
| f. Whether one electric and one diesel pump of 3 kg/cm pressure of capacity 1620 LPM, one electric pump of capacity 180 LPM exist near underground static tank. | ✓
Yes/No |
| g. Whether a pump 3 kg/cm pressure and 450/500 LPM exist near over head tank. | ✓
Yes/No |

Principal *[Signature]*
Sri Guru Teg Bahadur Public School
Khankot, Asst. Affiliation No. 1630055
06/05/2021

**Part-41
(To be filled by the SDE OF PWD)**

- I have visited the above mentioned school of dated 13/05/2021 and have visually inspected it from all angles for safety and find it fit for normal use as school building.
- In case any addition/alteration or expansion and modifications to this building is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- In case the building is affected by flood, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- The building can be safely occupied for normal use upto (Indicate into which it can be used) 31/05/2022

Principal *[Signature]*
Sri Guru Teg Bahadur Public School
Khankot, Asst. Affiliation No. 1630055
06/05/2021

Principal Singh
Sub Divisional Engineer,
Provincial Sub Division No. 3
P.W.D. B&R Branch, Amritsar